

**Council Email Poll
September 14, 2017**

Present

Mayor L. Boucher
Deputy Mayor W. Cormier
Councillor M. Farrell
Councillor A. Murray
Councillor D. MacInnis
Councillor J. MacPherson
Councillor D. Roberts

Also Present

D. Wilson, Deputy Clerk

Deputy Clerk D. Wilson called the meeting to order, provided background information as follows:

The existing Clydesdale watermain crossing dates back to the 1900s with the former water supply from the Clydesdale system. There are approximately a dozen properties serviced from the 12 inch main from the Pleasant Valley intersection to Back Road Brierly Brook.

The current condition of the 70 foot watermain crossing is reported in poor condition with portions of the main exposed and missing concrete surround. The pipe materials are reportedly thinning and several pipe joints are visible, making potential for a mainbreak increasing, likely within a year.

D. Wilson then put forth the following motion:

“That the Town fund Option #2 as presented which would undertake a directional drill 50 feet upstream of current crossing and reconnect to existing systems at an estimated cost of \$65000-\$75000.” Motion carried.

With there being no further business the meeting was adjourned.